



Kielichy: 15 (Tulips)
 Wystawanie kolanek: 28 +2 -5 (U-Bends)
 Wystawanie rurki obiegowej: 14 +2 -5 (Hairpins)

27.09.2021 Tomi Sipilä

SLOT 6,5x13 (3+3)

STATUS: Pending	CHANGE NR.:	CHANGE REASON: 4040/6039351 Creation	CHANGE DATE-HOUR: 23-Sep-2021 11:53	ISSUE: 00
		4040/6039351 Creation	21-Sep-2021 13:32	00
GENERAL TOL.: ISO 2768-c	PROJECTION: ⊕	MATERIAL CODE: 10239794	CUSTOMER: CAVF 72/REPAIR	
DESCRIPTION: 05G1720P021L0180R02T09C0F0				
TREATMENT:	COLOR:		SEST-LUVE-POLSKA sp. z o.o. Gliwice ul. Wyczółkowskiego 30 (ZIP Code 44-109) Poland Tel: +48 (0)32 3304050 - Fax: +48 (0)32 3304030 www.sest.it - e-mail: sestlurvepolska@lurvegroup.com	
WEIGHT: 1.5 kg	DRAW DATE: 23/09/2021	APPROVED BY: B.Konsek	DRAW BY: M.Kurzyca	

CUSTOMER MATERIAL CODE 20192206	TEST PRESSURE 30 Bar	GEOMETRY	TUBE CU Ø5	Grooved
CUSTOMER DRAWING Nr	PS REF. TO PED 30 Bar	TUBE x ROW SPACE 20x17,3 mm	FINS AL	Louvered
NITROGEN CHARGE NO	DESIGN PRESSURE REF. TO UL	Nr OF TUBES Nr OF ROWS 9 2	END PLATES Thk. 1 mm FEZN	
REFRIGERANT PEDgr1 - PED FLUID GROUP 1	TS MIN TS MAX -40 °C +125 °C	FIN SPACE 2.1 mm	COVER PLATES	

This drawing is the property of LU-VE Group, any reproduction and/or distribution without LU-VE Group approval is unlawful.

TOLERANCES FOR CONNECTIONS UNLESS OTHERWISE SPECIFIED: ±3 mm, ±3° Technical specification according SPEC1 - Last rev.