



Dryers for refrigeration and air conditioning
 Via Vernea, 30 - 10042 Nichelino (TO) Italy - Tel. +39 011 6800347 Fax +39 011 6800341
 e-mail: interdryers@interdryers.com - web page www.interdryers.com
 VAT No. IT 00705990018

QUALITY CONTROL CERTIFICATE

Customer Part number	Interdryers code	Quantity	Ref. Delivery Note
		5	
Customer	Description	Lot nr.	N.
Repair OY - Finland	DRYER GR. 15, 2 exit, Cu tube Ø19x118 - Th:0,50 mm Ø 19 Molsiv® XH-9	18/09/2019	
Order / Request	Filter screen 150 mesh	Manufacturing Date	Date
Att. To Mr Saul Mustakallio email request dd 22/07/2019		18/09/2019	

CERTIFICATE TYPE

- SAMPLES FIRST PRODUCTION LOT NON-CONFORMITY ADVICE
 DEROGATION REGULAR TESTING RANDOM TESTING

Modification	Enclosed testing reports
<input type="checkbox"/> DRAWING <input type="checkbox"/> HANDLING <input type="checkbox"/> TOOLS <input type="checkbox"/> MATERIAL	<input type="checkbox"/> YES Note <input type="checkbox"/> NO

No Ref	Test Specification	UM	Nominal Value	LSL or min	USL or max	N. Tested Items	Result		Notes
							Positive	Negative	
1	Molecular Sieve Weight UOP Honeywell XH9	gr	15	14	16	5,00	OK		
2	Moisture Max	%	1,5		1,5	5,00	OK		
3	Crush average value	lbs	12	12		5,00	OK		
4	Water adsorption Capacity each gr.	%	15	15		5,00	OK		
5	Lenght	mm	118	114	122	5,00	OK		
6	Hole/s In	mm	5,00	5,00	5,20	5,00	OK		
7	Hole/s Out	mm	2,50	2,50	2,60	5,00	OK		
8									
9									
10									
11									
12									
13									
14									

Remarks:

Operator	Quality control manager	Date
A.Salis	Roberto Ballardini	18/09/2019

Approved
 Viessmann Refrigeration Systems Oy
 Keijo Kurki 03.12.2019